## AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N. 43 006 014 106

1st Floor. 191 Racecourse Road, Flemington, Victoria 3031 P.O. Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

## **TEST REPORT**

CLIENT :

3M AUSTRALIA PTY LTD PO BOX 99

PYMBLE NSW 2073

TEST NUMBER

7-553990-BN

DATE

02/08/2007

ORDER NUMBER :

S56781

REPLACEMENT OF REPORT NO 7-551253-BN DATED 20/03/2007

SAMPLE DESCRIPTION

Clients ref: DiNoc film - Metallic pattern Film with self adhesive backing submitted Nominally: PVC with embossed PVC overlaminate

AS/NZS 3837:1998

Method of Test for Heat and Smoke Release Rates for Materials and Products Using an Oxygen

Results: -

Specimen 2

3

Mean

Averate Heat Release Rate

1 36.3

39.5

35.7

37.2

kW/m2

Average Specific extinction area

190.7 165.9

Consumption Calorimeter

155.3

170.6

(according to Specification C1.10 of the Building Code of Australia)

BCA Classification: -

Group Classification

(according to Specification A2.4 of the Building Code of Australia)

162428

(CONTINUED NEXT PAGE)

PAGE

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



This Laboratory is accredited by the National Association of Testing Authorities, Australia, for

- Chemical Testing of Textiles & Related Products - Mechanical Testing of Textiles & Related Products

Accreditation No. 983 Accreditation No. Accreditation No. 1356

- Heat & Temperature Measurement This document is issued in accordance with NATA's accreditation requirements. Samples, and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in

advertising providing the content and format of the advertisement have been approved in advance by the Managing Director of AWTA Ltd.

andolac

APPROVED SIGNATORY



A. JACKSON B.Sc.(Hons) MANAGING DIRECTOR